

333-061-0031

Maximum Residual Disinfectant Levels

Table 7

Disinfectant Residual:	MRDL in mg/l:
Chlorine	4.0 (as Cl ₂)
Chloramines	4.0 (as Cl ₂)
Chlorine dioxide	0.8 (as ClO ₂)